



Bid Addendum

Page 1 of 1

ADDENDUM NO.: 3

DATE OF ADDENDUM: January 08, 2015

**Town of Mansfield, Connecticut
Storrs Center Town Square Structural Elements Bid**

Original Bid Due Date / Time: January 8, 2015 at 2:00 PM

Revised Bid Due Date / Time: January 13, 2015 at 2:00 PM

TO: Prospective Bid Proposers:

This Addendum forms part of the "Contract Documents" and modifies or clarifies the original "Contract Documents" for this Project dated December 2015. Prospective Bid Proposers shall acknowledge receipt of the total number the Addenda issued for this Project on the space provided on the Bid Form/Proposal. Failure to do may subject Bid Proposers to disqualification.

The following clarifications are applicable to drawings and specifications for the project referenced above.

Item 1

Question: What is the thickness of the tie rods?

The tie rods as specified on the S-1 sheets call for DT-S460, 20, K-40 rods. 20 is the diameter in millimeters or 13/16 inches..

Item 2

Question: What is the finish on the structure?

The finish for all structural steel is hot dipped galvanized. Note #5 under structural steel on sheet S-1 is incorrect and should be ignored.

All questions must be in writing and must be forwarded to the Town of Mansfield Director of Public Works, John C. Carrington at 860-429-3332 or via e-mail at John.Carrington@mansfieldct.org.

End of Addendum No. 3