

BUILDING NOTES

1. ANNUAL RATED GLAZING FIRE RESISTING TO BE PROVIDED IN EACH UNIT. FIRE EXTINGUISHERS ARE TO BE LOCATED EVERY 75' IN CORRIDORS.
2. CONTROL JUNCTIONS SHOULD BE SPACED IN PERSONAL WALL JOINTS ARE RECOMMENDED AT DOOR JAMBS, EXTENDING FROM DOOR HEAD TO CEILING. CEILING GYPSUM BOARD 5/8" SF MAX. AND 90° EITHER DIRECTION. CONTROL JUNCTIONS SHOULD BE STAYED WHERE THERE IS A CHANGE IN CONTROL JOINTS AT THE CEILING AND WALL PER THE MANUFACTURER'S RECOMMENDED INSTALLATION INSTRUCTIONS. CONTROL JOINTS SHOULD BE LOCATED AT STRUTTED CONNECTION POINTS AND THE TOP AND BOTTOM OF ALL WINDOW RAMPS.
3. WHERE STAIR EGT IS WITHIN 2'-0" OF AN ALCOVE, FROM A DOORWAY TO OBSERVE IN THE MIRROR THE AREA AROUND THE DOORWAY OR WITHIN THE ALCOVE THAT IS ADJACENT TO THE DOORWAY.
4. ALL ACCESSIBLE ENTRANCES SHALL HAVE NO MORE THAN A 2% SLOPE FOR A DISTANCE OF 60' PERPENDICULAR TO THE DOORWAY.
5. ALL EXTERIOR COMMON USE DOOR THRESHOLDS TO BE ACCESSIBLE. REF: 1A.108 AND 1A.610 FOR TYPICAL DOOR THRESHOLD COMMON USES.
6. MANUFACTURER'S RECOMMENDED INSTALLATION ON THE NUMBERED PLANS. REFER TO A3.00 SHEETS FOR UNIT, A3.00 SHEETS FOR CLUB FINISHES, AND A6.00 SHEETS FOR STAIRS, ELEVATORS, AND FINISH ROOMS.

SYMBOL LEGEND - BLDG PLANS

