

- A. Amend: **505.1 General.** Every sink, lavatory, bathtub or shower, drinking fountain, water closet or other plumbing fixture shall be properly connected to either a public water system or to an approved private water system. All kitchen sinks, lavatories, laundry facilities, bathtubs and showers shall be supplied with hot or tempered and cold running water in accordance with the Building Code and Regulations listed in Chapter 8.
- B. Add: **505.2.1. Water test.** Prior to a rental certificate being issued pursuant to Chapter 9 of this code, a copy of a water test completed within the immediately preceding 24 months indicating that the water supply meets the following minimum standards must be submitted to the Code Official: [Amended 3-26-2007, effective 4-20-2007]

Chloride: less than or equal to 250 mg/l
Nitrate: less than or equal to 10 mg/l
Nitrite: less than or equal to 1.0 mg/l
Manganese: less than or equal to 0.5 mg/l
Chlorine, residual: less than .05 mg/l
Coliform bacteria: 0 col/100 ml

The sample must be drawn and tested by a firm certified by the State of Connecticut Department of Public Health to perform such duties. The provisions of this section shall not apply to dwelling units that are served by a public water supply or are regulated by the Water Quality Monitoring Schedule directed by the Connecticut Department of Public Health.

CODE OF THE TOWN OF MANSFIELD CONNECTICUT, v10.3 Updated 08-15-2009 / PART II GENERAL LEGISLATION / Chapter 130, HOUSING CODE / ARTICLE II, Amendments to Code / § 130-29. Section 506, Sanitary Drainage System. [Amended 4-27-2009, effective 5-22-2009]

§ 130-29. Section 506, Sanitary Drainage System. [Amended 4-27-2009, effective 5-22-2009]

Add to SECTION 506, SANITARY DRAINAGE SYSTEM: **506.3 Private Sewage Disposal System Maintenance.** Prior to a rental certificate being issued pursuant to Chapter 9 of this code, a report provided by a pumper/hauler licensed by the Connecticut Department of Public Health, demonstrating that the on-site sewage disposal system has been cleaned and serviced within the past four years, must be submitted to the Code Official. The provisions of this section